

TEST CERTIFICATE

ST-18-08-29-02

Product: Laminate floor covering
Quick Step "Impressive", class 32
Dimensions: 1380 mm x 190 mm x 8 mm

Producer: Unilin Flooring BV, Ooigemstraat 3, 8710 Wielsbeke, Belgium

Order: Determination of selected properties according to EN 13329:2016

Test report: 2716542/1 from 25/10/2017

Test results:

- The general requirements according to EN 13329:2016 Table 1 are fulfilled.
- The classification requirements according to EN 13329:2016 Table 2 of the following levels of use are fulfilled:


Resistance against abrasion:	classes 21-23 and 31-32
Resistance against impact small ball:	classes 21-23 and 31-33
Resistance against impact big ball:	classes 21-23 and 31-33
Resistance against staining:	classes 21-23 and 31-34
Resistance against movement of a furniture leg:	classes 21-23 and 31-34
Resistance against soft chair rolls:	classes 21-23 and 31-33
Thickness swelling:	classes 21-23 and 31-33
Locking strength short side joints:	classes 21-23 and 31-34
Locking strength long side joints:	classes 21-23 and 31-34
Surface soundness:	classes 21-23 and 31-34

Dresden, 10/09/2018



Head of laboratory





Engineer in charge