

No. 1467233.1

(Please quote this number in all correspondence)

CLIENT:
Floorscape Ltd.
PO Box 302365
North Harbour 0751
Auckland

SAMPLE RECEIVED FROM:
Floorscape Ltd.

Date Received: 4.7.23

SAMPLE DESCRIPTION:
Flooring Planks – Quick-Step Muse

Attn.: Mike Caird

Client Order No.:

Client Reference:

1 of 2

**AS 4586-2013 – SLIP RESISTANCE CLASSIFICATION OF NEW PEDESTRIAN SURFACE MATERIALS
Appendix A – Wet Pendulum Test Method**

Note: This test was sub-contracted (Test Number 23-002659).

Test Temperature: 21°C
Sample Preparation: Washed with pH neutral detergent and dried.
Test Direction: Width
Fixed/Unfixed: Unfixed
Slider Used: Slider 96, Batch No. 15

Width:	1	2	3	4	5	SRV (Slip Resistance Value)
British Pendulum Number:	33	31	29	33	32	32

Classification: P2


Table 2: Classification of Pedestrian Surface Materials According to the AS 4586 Wet Pendulum Test

Class	Pendulum SRV	
	Slider 96	Slider 55
P5	>54	>44
P4	45-54	40-44
P3	35-44	35-39
P2	25-34	20-34
P1	12-24	<20
P0	<12	

These results apply only to the specimens tested and it is recommended that before selection of flooring or paving materials the effect of service condition, including maintenance and wear on their slip resistance be checked.

“THIS REPORT APPLIES ONLY TO THE SAMPLES TESTED”

Samples and their identifying descriptions have been provided by the client unless otherwise stated. NZWTA Ltd makes no warranty, implied or otherwise as to the source of the tested samples. The above results are designed to provide THE CLIENT WITH GUIDANCE INFORMATION ONLY. This document shall not be reproduced except in full.


C Judan
Key Technical Person

20/07/2023

No. 1467233.1

(Please quote this number in all correspondence)

CLIENT:
Floorscape Ltd.
PO Box 302365
North Harbour 0751
Auckland

SAMPLE RECEIVED FROM:
Floorscape Ltd.

Date Received: 4.7.23


SAMPLE DESCRIPTION:
Flooring Planks – Quick-Step Muse

Attn.: Mike Caird

Client Order No.:

Client Reference:

2 of 2



"THIS REPORT APPLIES ONLY TO THE SAMPLES TESTED"

Samples and their identifying descriptions have been provided by the client unless otherwise stated. NZWTA Ltd makes no warranty, implied or otherwise as to the source of the tested samples. The above results are designed to provide THE CLIENT WITH GUIDANCE INFORMATION ONLY. This document shall not be reproduced except in full.


C Judan
Key Technical Person

20/07/2023